

18-4143-00: Hot Springs, AR 2025 SSES

Smoke Observation Summary

Cleanout, Missing/Broken Cap

Address: 651 Fourth St

Basin: **HS62**

Segment (US : DS): **9999:2419**


Intensity: **High**

Drainage Area (SF): **20**

Surface: **Paved**

Comments:

QC Comments: Need close up without smoke to verify defect



Cleanout, Missing/Broken Cap

Address: 645 Fourth St

Basin: **HS62**

Segment (US : DS): **9999:2419**

Intensity: **Medium**

Drainage Area (SF): **20**

Surface: **Unpaved**

Comments:

QC Comments: Need close up verifying defect

