

## 30-3676-04: Tulsa Metropolitan Utility Authority (TMUA) FY26 On-Call

### Smoke Observation Summary

#### Cleanout, Defective

Address: 10138 E 25th St

Basin: **83-N**

Segment (US : DS): **083-0182:083-0181**


Intensity: **Medium**

Drainage Area (SF): **0**

Surface: **Unpaved**

Comments: *Smoking area*

*QC Comments: Cannot see where cleanout is broken, may be loose cap*



#### Cleanout, Defective

Address: 10135 E 26th St

Basin: **83-N**

Segment (US : DS): **083-0126:083-0125**

Intensity: **Low**

Drainage Area (SF): **0**

Surface: **Unpaved**

Comments:

*QC Comments: Smoke not visible in photos, verify rim to grade*

